

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269431	25' SW OF TW 69-Z; 432'E OF WORTH ST JOHN LEONARD PARK 186 N OF B&W RR TRACKS	7/28/1969

Owner-Contractor	Name	Address	Telephone
Owner	CITY OF SPEEDWAY	SPEEDWAY	Not available
Driller	LAYNE NORTHERN CO INC	MISHAWAKA IN	Not available
Operator	BOB COLLINS & HARRY SMITH	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 66.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 58.0	Material: Not available	Diameter: 18.0
Screen	Length: 10.0	Material: Not available	Diameter: 18.0
	Slot Size: COOKWW 0.125		

Well Capacity Test	Type of Test: Not available	Test Rate: 578.0 gpm for 8.0 hrs.	Bail Test Rate: Not available
	Drawdown: 30.0 ft.	Static Water Level: 10.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION Range: 2E Topo Map: CLERMONT Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: UCH Subdivision Name: SPEEDWAY Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: 725.0 Bedrock Elevation: Not available UTM Easting: 563929	Township: 16N Section: SW of the NE of the SE of Section 36 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: 10/5/1971 Lot Number: #7 Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: 659.0 UTM Northing: 4403983
-----------------------	---	--

Well Log

Top	Bottom	Formation
0.0	7.0	CLAY
7.0	29.0	S&G
29.0	50.0	CLAY
50.0	66.0	CRS S&G

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
177016	770 FEET N OF #13 WELL 167 FT S OF 21ST; 252 FT W OF TOE OF LEVEE; 770 FT N OF #13 WELL	8/1/1972

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	INDPLS, IN	Not available
Operator	ROBERT COLLINS AND EGING ALLEN	License Not available	

Construction Details

Well	Use: Public Supply	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 56.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 50.0	Material: Not available	Diameter: 18.0
Screen	Length: 10.0	Material: Not available	Diameter: 18.0
	Slot Size: SS WW .090		

Well Capacity Test	Type of Test: Pumping	Test Rate: 524.0 gpm for 8.0 hrs.	Bail Test Rate: Not available
	Drawdown: 40.0 ft.	Static Water Level: 9.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: NW of the NE of the NW of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: WCH	Location Accepted w/o Verification On: 2/1/1973
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 723.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 667.0
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
-----	--------	-----------

0.0	4.0	GRAY CLAY
4.0	11.0	COARSE S & G
11.0	13.0	GRAY CLAY
13.0	40.0	COARSE S & G
40.0	45.0	GRAY CLAY
45.0	56.0	MED SAND COARSE GRAV GRAY

Comments

CASING
EXTENDS
ABOVE
GROUND;
ADDT'L
INFORMATION
STAPLED TO
LOG

Record of Water Well Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
176996	BOY SCOUT CAMP, 310' W OF MICKLEY AVE, 95' N OF RR TRACKS	12/24/1971

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	Not available	Not available
Driller	LAYNE NORTHERN	INDPLS., IN	Not available
Operator	H. FOSTER, ROBERT COLLINS	License Not available	

Construction Details			
Well	Use: Public Supply Depth: Not available	Drilling Method: Not available Pump Setting Depth: Not available	Pump Type: Not available Water Quality: Not available
Casing	Length: 53.4	Material: Not available	Diameter: 36.0
Screen	Length: 8.0 Slot Size: Not available	Material: Not available	Diameter: 20.0

Well Capacity Test	Type of Test: Not available Drawdown: Not available	Test Rate: Not available Static Water Level: 13.0 ft.	Bail Test Rate: Not available Bailer Drawdown: Not available
---------------------------	--	--	---

Grouting Information	Material: Not available Installation Method: Not available	Depth: From (not available) To (not available) Number of Bags Used: Not available
-----------------------------	---	--

Well Abandonment	Sealing Material: Not available Installation Method: Not available	Depth: From (not available) To (not available) Number of Bags Used: Not available
-------------------------	---	--

Administrative	County: MARION Range: 2E Topo Map: CLERMONT Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: 36 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	---	---

Well Log

Top	Bottom	Formation
0.0	10.0	TOP SOIL, SANDY CLAY
10.0	25.0	S & G
25.0	50.0	GRAY CLAY & BOULDERS
50.0	60.0	S & G

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269435	310' W OF MICKLEY AV 95'N OF RR TRACKS BOY SCOUT CAMP	12/24/1971

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE-NORTHERN CO INC	MISHAWAKA IN	Not available
Operator	H FOSTER, ROBERT COLLINS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 60.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 57.0	Material: Not available	Diameter: 36.0
Screen	Length: 8.0	Material: Not available	Diameter: 18.0
	Slot Size: J SS .090		

Well Capacity Test	Type of Test: Not available	Test Rate: 596.0 gpm	Bail Test Rate: Not available
	Drawdown: 34.0 ft.	Static Water Level: 13.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: NE of the NE of the SW of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: UCH	Location Accepted w/o Verification On: 2/1/1973
	Subdivision Name: SPEEDWAY	Lot Number: #10
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 725.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 665.0
	UTM Easting: 563254	UTM Northing: 4404094

Well Log

Top	Bottom	Formation
0.0	10.0	TOP SOIL SANDY CLAY
10.0	25.0	S&G
25.0	50.0	GRAY CLAY & BOULDERS
50.0	60.0	S&G

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269434	200' OF RR TRACKS & 40' E OF LEVEE ON E SIDE OF EAGLE CREEK	12/17/1971

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE-NORTHERN CO INC	MISHAWAKA IN	Not available
Operator	ROBERT COLLINS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 60.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 56.0	Material: Not available	Diameter: 36.0
Screen	Length: 9.0	Material: Not available	Diameter: 18.0
	Slot Size: J SS .090		

Well Capacity Test	Type of Test: Not available	Test Rate: 305.0 gpm	Bail Test Rate: Not available
	Drawdown: 33.0 ft.	Static Water Level: 17.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative County: MARION Range: 2E Topo Map: CLERMONT Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: UCH Subdivision Name: SPEEDWAY #9 Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: 725.0 Bedrock Elevation: Not available UTM Easting: 562812	Township: 16N Section: NE of the NW of the SW of Section 36 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: 2/1/1973 Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: 665.0 UTM Northing: 4404116
---	--

Well Log

Top	Bottom	Formation
0.0	15.0	S&G & BOULDERS
15.0	51.0	BR CLAY
51.0	53.0	FINE GRAV
53.0	60.0	MED S&G

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269427	30' E THEN 130' N OF NE CORNER OF PRESENT PUMP HOUSE	6/13/1935

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY CITY	SPEEDWAY IN	Not available
Driller	LAYNE NORTHERN CO	MISHAWAKA IN	Not available
Operator	MACK YOUNG	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 78.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 46.0	Material: Not available	Diameter: 50.0
Screen	Length: 30.0	Material: Not available	Diameter: 26.0
	Slot Size: #4		

Well Capacity Test	Type of Test: Not available	Test Rate: 1,200.0 gpm	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative County: MARION Range: 2E Topo Map: CLERMONT Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: SPEEDWAY Ft W of EL: 100.0 Ft E of WL: Not available Ground Elevation: 724.0 Bedrock Elevation: Not available UTM Easting: 564121	Township: 16N Section: SE of the NE of the SE of Section 36 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: #2 Ft N of SL: 1,800.0 Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: 648.0 UTM Northing: 4403908
--	--

Well Log

Top	Bottom	Formation
0.0	5.0	SOIL & CLAY
5.0	14.0	SAND

14.0	27.0	S&G
27.0	31.0	HARD GRITTY CLAY
31.0	38.0	MED S&G
38.0	48.0	S&G
48.0	65.0	CRS S&G
65.0	76.0	GRAY S&G
76.0	76.5	BLUE CLAY

Comments

P.L =43':

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269430	60' W OF SW LEG OF WATER TOWER.	6/16/1950

Owner-Contractor	Name	Address	Telephone
Owner	TOWN OF SPEEDWAY	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	D SMITH	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 70.7	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 48.0	Material: Not available	Diameter: 42.0
Screen	Length: 20.0	Material: Not available	Diameter: 18.0
	Slot Size: #5		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: 662.0 gpm
	Drawdown: Not available	Static Water Level: 17.0 ft.	Bailer Drawdown: 21.0 ft.

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SE of the NE of the SE of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: SPEEDWAY	Lot Number: #6
	Ft W of EL: 150.0	Ft N of SL: 1,600.0
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 724.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 656.0
	UTM Easting: 564109	UTM Northing: 4403873

Well Log

Top	Bottom	Formation
0.0	4.0	TOP SOIL
4.0	6.0	MED SAND

6.0	7.0	MED TO CRS GRAV CRS SAND
7.0	8.0	RED CLAY
8.0	13.0	BLUE CLAY
19.0	26.0	MED GRAV & CRS SAND
26.0	44.0	CLAY
44.0	50.0	MED SAND & FN GRAV & BOULDER
50.0	53.0	CLAY
53.0	58.0	CRS SAND & FINE GRAV
58.0	59.0	CRS SAND & CRS GRAV
59.0	64.0	CRS SAND & FINE TO MED GRAF
64.0	70.7	CRS S&G

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
201736	APPROX 200FT N OF 16TH ST AND 20FT W OF GENT AVE	3/21/1995

Owner-Contractor	Name	Address	Telephone
Owner	INDIANAPOLIS WATER CO	1220 WATERWAY BLVD INDIANAPOLIS IN	(317)263-6361
Driller	ORTMAN DRILLING INC	241N CO RD 300W KOKOMO IN	(317)459-4125
Operator	RICK O RUSSELL MCVAN K	License: 330 1036	

Construction Details

Well	Use: Public Supply	Drilling Method: Rotary	Pump Type: Not available
	Depth: 97.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 77.0	Material: SS	Diameter: 16.0
Screen	Length: 20.0	Material: SS	Diameter: 16.0
	Slot Size: .080		

Well Capacity Test	Type of Test: Pumping	Test Rate: Not available	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information	Material: BNSL	Depth: From 50.0 To 14.0
	Installation Method: Not available	Number of Bags Used: 10.0

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: SW of the NE of Section 34
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	7.0	BR CLAY
7.0	25.0	SAND & FINE-MD GRAV

25.0	30.0	SAND & FINE GRAV
30.0	35.0	SAND & LIGHT CLAY
35.0	41.0	LIGHT SAND & MD-BIG GRAV
41.0	54.0	GRAY CLAY
54.0	96.0	SAND & F-M GRAV 72-75 SAND
96.0	100.0	GRAY LS

Comments

GRAVEL PACK
ADD'L CONSTR
INFO ON LOG

Record of Water Well
Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269430	60' W OF SW LEG OF WATER TOWER.	6/16/1950

Owner-Contractor	Name	Address	Telephone
Owner	TOWN OF SPEEDWAY	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	D SMITH	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 70.7	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 48.0	Material: Not available	Diameter: 42.0
Screen	Length: 20.0	Material: Not available	Diameter: 18.0
	Slot Size: #5		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: 662.0 gpm
	Drawdown: Not available	Static Water Level: 17.0 ft.	Bailer Drawdown: 21.0 ft.

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SE of the NE of the SE of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: SPEEDWAY	Lot Number: #6
	Ft W of EL: 150.0	Ft N of SL: 1,600.0
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 724.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 656.0
	UTM Easting: 564109	UTM Northing: 4403873

Well Log

Top	Bottom	Formation
0.0	4.0	TOP SOIL
4.0	6.0	MED SAND

6.0	7.0	MED TO CRS GRAV CRS SAND
7.0	8.0	RED CLAY
8.0	13.0	BLUE CLAY
19.0	26.0	MED GRAV & CRS SAND
26.0	44.0	CLAY
44.0	50.0	MED SAND & FN GRAV & BOULDER
50.0	53.0	CLAY
53.0	58.0	CRS SAND & FINE GRAV
58.0	59.0	CRS SAND & CRS GRAV
59.0	64.0	CRS SAND & FINE TO MED GRAF
64.0	70.7	CRS S&G

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
177422	163' W & 10' S OF NORTHWEST CORNER OF CHEMICAL HOUSE	7/23/1936

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	JAMES NESS	License Not available	

Construction Details			
Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 78.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: 38.0
Screen	Length: 38.0	Material: Not available	Diameter: 38.0
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: 2,650.0 gpm	Bail Test Rate: Not available
	Drawdown: 26.0 ft.	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: NW of Section 35
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log Comments
 (ADD'L INFO
 STAPLED TO
 LOG)(WATER CO
 TEST 1 SITE 1)

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
177422	163' W & 10' S OF NORTHWEST CORNER OF CHEMICAL HOUSE	7/23/1936

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	JAMES NESS	License Not available	

Construction Details	Well	Drilling Method: Not available	Pump Type: Not available
	Use: Not available	Pump Setting Depth: Not available	Water Quality: Not available
	Depth: 78.0		
	Casing	Material: Not available	Diameter: 38.0
	Screen	Material: Not available	Diameter: 38.0
	Length: Not available		
	Length: 38.0		
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: 2,650.0 gpm	Bail Test Rate: Not available
	Drawdown: 26.0 ft.	Static Water Level: Not available	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: NW of Section 35 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	---

Well Log Comments	(ADDT'L INFO STAPLED TO LOG)(WATER CO TEST 1 SITE 1)
--------------------------	---

Record of Water Well

Indiana Department of Natural Resources

WR4

Reference Number	Driving Direction to Well	Date Completed
177427	APPROX 1100' W OF W STREET AND 50' N OF 16TH ST	9/18/1941

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	WILLIAM WAGNER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 80.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 37.0	Material: Not available	Diameter: 54.0
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: 930.0 gpm	Bail Test Rate: Not available
	Drawdown: 14.0 ft.	Static Water Level: 14.5 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: NE of the NW of the NW of Section 35 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	---

Well Log

Top	Bottom	Formation
0.0	10.0	TOP SOIL & CLAY
10.0	47.0	S&G
47.0	62.0	HARD CLAY

62.0	77.0	COARSE S&G
77.0	80.0	BOULDERS & CLAY

Comments

(#4)(ADDT'L
INFO STAPLED
TO LOG)

WR 7

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
177486	75' N OF PUMPING STATION WELL & 35' E OF FENCE	7/8/1967

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	E. ALLEN	License Not available	

Construction Details			
Well	Use: Public Supply	Drilling Method: Not available	Pump Type: Not available
	Depth: 77.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: Not available
Screen	Length: 20.0	Material: Not available	Diameter: 36.0
	Slot Size: #4		

Well Capacity Test	Type of Test: Not available	Test Rate: 2,146.0 gpm	Bail Test Rate: Not available
	Drawdown: 28.0 ft.	Static Water Level: 20.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: NW of Section 35
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: UCH	Location Accepted w/o Verification On: 5/25/1970
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log Comments
None

Record of Water Well

Indiana Department of Natural Resources

WR8

Reference Number	Driving Direction to Well	Date Completed
177481	675 FEET SOUTH OF AND 50 FT. WEST OF WELL #7	7/14/1967

Owner-Contractor	Name	Address	Telephone
Owner	INDIANAPOLIS WATER CO.	Not available	Not available
Driller	LAYNE NORTHERN	INDIANAPOLIS IN	Not available
Operator	JOHN STEPP	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: 78.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: Not available
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: 35.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: 35
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	1.0	ROCKS
1.0	8.0	BRN GRAVELY CLAY
8.0	41.0	YEL GRAV
41.0	44.0	GRAY GRAV

44.0	49.0	GRAY SAND
49.0	53.0	GRAY SAND & GRAV
53.0	60.0	GRAY CLAY
60.0	78.0	BLUE GRAV

Comments

None

Record of Water Well

Indiana Department of Natural Resources

w n g

Reference Number	Driving Direction to Well	Date Completed
177501	WHITE RIVER STATION FILTRATION PLANT - 150 FT. SOUTH OF #1 WELL AND 150 FEET E OF MICHIGAN AUTO PART ROAD., 940 W. 16TH	11/20/1974

Owner-Contractor	Name	Address	Telephone
Owner	INDIANAPOLIS WATER CO.	Not available	Not available
Driller	LAYNE NORTHERN	INDIANAPOLIS IN	Not available
Operator	WILLIAM WELLS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 79.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 81.0	Material: Not available	Diameter: 30.0
Screen	Length: 20.0	Material: Not available	Diameter: 30.0
	Slot Size: 5.5		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: 13.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION
	Range: 3E
	Topo Map: INDIANAPOLIS WEST
	Field Located By: WDH
	Courthouse Location By: Not available
	Location Accepted w/o Verification By: Not available
	Subdivision Name: Not available
	Ft W of EL: Not available
	Ft E of WL: 500.0
	Ground Elevation: 700.0
	Bedrock Elevation: 621.0
	UTM Easting: 570539.4
	Township: 16N
	Section: SW of the NW of the NW of Section 35
	Grant: Not available
	Field Located On: 7/26/1976
	Courthouse Location On: Not available
	Location Accepted w/o Verification On: Not available
	Lot Number: Not available
	Ft N of SL: Not available
	Ft S of NL: 850.0
	Depth of Bedrock: 79.0
	Aquifer Elevation: Not available
	UTM Northing: 4404910

Well Log

--	--	--	--

Top	Bottom	Formation
0.0	10.0	SAND & MED. GRAV
10.0	15.0	CRS. GRAV
15.0	21.0	MED. GRAV
21.0	25.0	CLAY & BOULDERS HARD GRAY ST.
25.0	35.0	CRS. GRAV SAME BOULDERS
35.0	42.0	MED. GRAV, SAME BOULDERS
42.0	55.0	HARD DRY GRITTY GRAY CLAY
55.0	63.0	CRS. SAND & GRAVEL
63.0	79.5	CRS. GRAVEL W/ MED./FINE SAND
79.5		HARD BROWN ROCK

Comments

MC

Record of Water Well

Indiana Department of Natural Resources

Speedway well 3

Reference Number 269428 **Driving Direction to Well** ABOUT 100' N OF CENTER OF 10TH ST 100' E OF CREEK **Date Completed** 5/3/1941

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	JOHN MILLER & WM WAGNER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 62.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 37.3	Material: Not available	Diameter: 42.0
Screen	Length: 10.0	Material: Not available	Diameter: 10.0
	Slot Size: #3		

Well Capacity Test	Type of Test: Not available	Test Rate: 500.0 gpm	Bail Test Rate: Not available
	Drawdown: 18.0 ft.	Static Water Level: 13.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SW of the SW of the SE of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: SPEEDWAY	Lot Number: #3
	Ft W of EL: 2,350.0	Ft N of SL: 100.0
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 725.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 678.0
	UTM Easting: 563422	UTM Northing: 4403425

Well Log

Top	Bottom	Formation
0.0	8.0	SOIL & DIRT
8.0	32.0	HARDPAN

32.0	36.0	MED GRAV
36.0	43.0	HARDPAN
43.0	50.0	FN S&G
50.0	64.0	MD S&G

Comments
PUMP TEST
DATA
AVAILABLE:

Speedway #9

Record of Water Well
Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269429	400' N OF EAGLE CREEK BRIDGE ON W 10TH ST.	7/15/1941

Owner-Contractor	Name	Address	Telephone
Owner	TOWN OF SPEEDWAY CITY	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	JOHN MILLER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 69.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 42.5	Material: Not available	Diameter: 42.0
Screen	Length: 10.0	Material: Not available	Diameter: Not available
	Slot Size: #3		

Well Capacity Test	Type of Test: Not available	Test Rate: 215.0 gpm	Bail Test Rate: Not available
	Drawdown: 24.0 ft.	Static Water Level: 31.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SW of the SW of the SE of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: SPEEDWAY	Lot Number: #4
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 729.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 677.0
	UTM Easting: 563449	UTM Northing: 4403559

Well Log

Top	Bottom	Formation
0.0	5.0	TOP SOIL
5.0	12.0	S&G

12.0	30.0	HARD PAN
30.0	32.0	CLAY
32.0	35.0	CRS GRAV
35.0	48.0	HARD PAN
48.0	55.0	FINE SAND
55.0	65.0	MED GRAV CLAY

Comments

None

Record of Water Well **Indiana Department of Natural Resources**

Speedwell #9

Reference Number	Driving Direction to Well	Date Completed
269433	2ND WELL S OF RR TRACKS 58'E OF EAGLE CREEK LEVEE, 1165' SE OF #9 WELL	12/21/1971

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE-NORTHERN CO INC	MISHAWAKA IN	Not available
Operator	H FOSTER & ROBERT COLLINS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 60.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 48.0	Material: Not available	Diameter: 36.0
Screen	Length: 12.0	Material: Not available	Diameter: 18.0
	Slot Size: J SS .090		

Well Capacity Test	Type of Test: Not available	Test Rate: 305.0 gpm	Bail Test Rate: Not available
	Drawdown: 32.5 ft.	Static Water Level: 10.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SW of the NE of the SW of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: UCH	Location Accepted w/o Verification On: 2/1/1973
	Subdivision Name: SPEEDWAY	Lot Number: #8
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 723.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 665.0
	UTM Easting: 563066	UTM Northing: 4403810

Well Log

Top	Bottom	Formation
0.0	15.0	TOP SOIL SAND & GRAV&LOGS
15.0	45.0	HARD CLAY & BOULDERS
45.0	48.0	FINE GRAV
48.0	58.0	MED S&G

Comments
None

Record of Water Well

Indiana Department of Natural Resources

WR4

Reference Number	Driving Direction to Well	Date Completed
177427	APPROX 1100' W OF W STREET AND 50' N OF 16TH ST	9/18/1941

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	WILLIAM WAGNER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 80.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 37.0	Material: Not available	Diameter: 54.0
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: 930.0 gpm	Bail Test Rate: Not available
	Drawdown: 14.0 ft.	Static Water Level: 14.5 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 3E Topo Map: INDIANAPOLIS WEST Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: Not available Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: Not available Bedrock Elevation: Not available UTM Easting: Not available	Township: 16N Section: NE of the NW of the NW of Section 35 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: Not available Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: Not available UTM Northing: Not available
-----------------------	--	---

Well Log

Top	Bottom	Formation
0.0	10.0	TOP SOIL & CLAY
10.0	47.0	S&G
47.0	62.0	HARD CLAY

62.0	77.0	COARSE S&G
77.0	80.0	BOULDERS & CLAY

Comments
(#4)(ADDT'L
INFO STAPLED
TO LOG)

Record of Water Well **Indiana Department of Natural Resources**

WR 7

Reference Number	Driving Direction to Well	Date Completed
177486	75' N OF PUMPING STATION WELL & 35' E OF FENCE	7/8/1967

Owner-Contractor	Name	Address	Telephone
Owner	INDPLS WATER COMPANY	Not available	Not available
Driller	LAYNE NORTHERN	MISHAWAKE, IN	Not available
Operator	E. ALLEN	License Not available	

Construction Details			
Well	Use: Public Supply	Drilling Method: Not available	Pump Type: Not available
	Depth: 77.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: Not available
Screen	Length: 20.0	Material: Not available	Diameter: 36.0
	Slot Size: #4		

Well Capacity Test	Type of Test: Not available	Test Rate: 2,146.0 gpm	Bail Test Rate: Not available
	Drawdown: 28.0 ft.	Static Water Level: 20.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: NW of Section 35
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: UCH	Location Accepted w/o Verification On: 5/25/1970
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log Comments
None

Record of Water Well

Indiana Department of Natural Resources

WR8

Reference Number	Driving Direction to Well	Date Completed
177481	675 FEET SOUTH OF AND 50 FT. WEST OF WELL #7	7/14/1967

Owner-Contractor	Name	Address	Telephone
Owner	INDIANAPOLIS WATER CO.	Not available	Not available
Driller	LAYNE NORTHERN	INDIANAPOLIS IN	Not available
Operator	JOHN STEPP	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Cable Tool	Pump Type: Not available
	Depth: 78.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: Not available	Material: Not available	Diameter: Not available
Screen	Length: Not available	Material: Not available	Diameter: Not available
	Slot Size: Not available		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: 35.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION	Township: 16N
	Range: 3E	Section: 35
	Topo Map: INDIANAPOLIS WEST	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: Not available	Lot Number: Not available
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: Not available	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: Not available
	UTM Easting: Not available	UTM Northing: Not available

Well Log

Top	Bottom	Formation
0.0	1.0	ROCKS
1.0	8.0	BRN GRAVELY CLAY
8.0	41.0	YEL GRAV
41.0	44.0	GRAY GRAV

44.0	49.0	GRAY SAND
49.0	53.0	GRAY SAND & GRAV
53.0	60.0	GRAY CLAY
60.0	78.0	BLUE GRAV

Comments
None

Record of Water Well

Indiana Department of Natural Resources

w 29

Reference Number	Driving Direction to Well	Date Completed
177501	WHITE RIVER STATION FILTRATION PLANT - 150 FT. SOUTH OF #1 WELL AND 150 FEET E OF MICHIGAN AUTO PART ROAD., 940 W. 16TH	11/20/1974

Owner-Contractor	Name	Address	Telephone
Owner	INDIANAPOLIS WATER CO.	Not available	Not available
Driller	LAYNE NORTHERN	INDIANAPOLIS IN	Not available
Operator	WILLIAM WELLS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 79.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 81.0	Material: Not available	Diameter: 30.0
Screen	Length: 20.0	Material: Not available	Diameter: 30.0
	Slot Size: 5.5		

Well Capacity Test	Type of Test: Not available	Test Rate: Not available	Bail Test Rate: Not available
	Drawdown: Not available	Static Water Level: 13.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION
	Range: 3E
	Topo Map: INDIANAPOLIS WEST
	Field Located By: WDH
	Courthouse Location By: Not available
	Location Accepted w/o Verification By: Not available
	Subdivision Name: Not available
	Ft W of EL: Not available
	Ft E of WL: 500.0
	Ground Elevation: 700.0
	Bedrock Elevation: 621.0
	UTM Easting: 570539.4
	Township: 16N
	Section: SW of the NW of the NW of Section 35
	Grant: Not available
	Field Located On: 7/26/1976
	Courthouse Location On: Not available
	Location Accepted w/o Verification On: Not available
	Lot Number: Not available
	Ft N of SL: Not available
	Ft S of NL: 850.0
	Depth of Bedrock: 79.0
	Aquifer Elevation: Not available
	UTM Northing: 4404910

Well Log

--	--	--

Top	Bottom	Formation
0.0	10.0	SAND & MED. GRAV
10.0	15.0	CRS. GRAV
15.0	21.0	MED. GRAV
21.0	25.0	CLAY & BOULDERS HARD GRAY ST.
25.0	35.0	CRS. GRAV SAME BOULDERS
35.0	42.0	MED. GRAV, SAME BOULDERS
42.0	55.0	HARD DRY GRITTY GRAY CLAY
55.0	63.0	CRS. SAND & GRAVEL
63.0	79.5	CRS. GRAVEL W/ MED./FINE SAND
79.5		HARD BROWN ROCK

Comments

MC

Record of Water Well

Indiana Department of Natural Resources

Speedway well 3

Reference Number	Driving Direction to Well	Date Completed
269428	ABOUT 100' N OF CENTER OF 10TH ST 100' E OF CREEK	5/3/1941

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	JOHN MILLER & WM WAGNER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 62.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 37.3	Material: Not available	Diameter: 42.0
Screen	Length: 10.0	Material: Not available	Diameter: 10.0
	Slot Size: #3		

Well Capacity Test	Type of Test: Not available	Test Rate: 500.0 gpm	Bail Test Rate: Not available
	Drawdown: 18.0 ft.	Static Water Level: 13.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SW of the SW of the SE of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: Not available	Location Accepted w/o Verification On: Not available
	Subdivision Name: SPEEDWAY	Lot Number: #3
	Ft W of EL: 2,350.0	Ft N of SL: 100.0
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 725.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 678.0
	UTM Easting: 563422	UTM Northing: 4403425

Well Log

Top	Bottom	Formation
0.0	8.0	SOIL & DIRT
8.0	32.0	HARDPAN

32.0	36.0	MED GRAV
36.0	43.0	HARDPAN
43.0	50.0	FN S&G
50.0	64.0	MD S&G

Comments
PUMP TEST
DATA
AVAILABLE:

Speedway #9

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving Direction to Well	Date Completed
269429	400' N OF EAGLE CREEK BRIDGE ON W 10TH ST.	7/15/1941

Owner-Contractor	Name	Address	Telephone
Owner	TOWN OF SPEEDWAY CITY	SPEEDWAY IN	Not available
Driller	LAYNE - NORTHERN CO	MISHAWAKA IN	Not available
Operator	JOHN MILLER	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Not available	Pump Type: Not available
	Depth: 69.5	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 42.5	Material: Not available	Diameter: 42.0
Screen	Length: 10.0	Material: Not available	Diameter: Not available
	Slot Size: #3		

Well Capacity Test	Type of Test: Not available	Test Rate: 215.0 gpm	Bail Test Rate: Not available
	Drawdown: 24.0 ft.	Static Water Level: 31.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)	
	Installation Method: Not available	Number of Bags Used: Not available	

Administrative	County: MARION Range: 2E Topo Map: CLERMONT Field Located By: Not available Courthouse Location By: Not available Location Accepted w/o Verification By: Not available Subdivision Name: SPEEDWAY Ft W of EL: Not available Ft E of WL: Not available Ground Elevation: 729.0 Bedrock Elevation: Not available UTM Easting: 563449	Township: 16N Section: SW of the SW of the SE of Section 36 Grant: Not available Field Located On: Not available Courthouse Location On: Not available Location Accepted w/o Verification On: Not available Lot Number: #4 Ft N of SL: Not available Ft S of NL: Not available Depth of Bedrock: Not available Aquifer Elevation: 677.0 UTM Northing: 4403559
-----------------------	---	--

Well Log

Top	Bottom	Formation
0.0	5.0	TOP SOIL
5.0	12.0	S&G

12.0	30.0	HARD PAN
30.0	32.0	CLAY
32.0	35.0	CRS GRAV
35.0	48.0	HARD PAN
48.0	55.0	FINE SAND
55.0	65.0	MED GRAV CLAY

Comments

None

Record of Water Well

Indiana Department of Natural Resources

Speedwell #9

Reference Number	Driving Direction to Well	Date Completed
269433	2ND WELL S OF RR TRACKS 58'E OF EAGLE CREEK LEVEE, 1165' SE OF #9 WELL	12/21/1971

Owner-Contractor	Name	Address	Telephone
Owner	SPEEDWAY WATER WORKS	SPEEDWAY IN	Not available
Driller	LAYNE-NORTHERN CO INC	MISHAWAKA IN	Not available
Operator	H FOSTER & ROBERT COLLINS	License Not available	

Construction Details

Well	Use: Not available	Drilling Method: Reverse Rotary	Pump Type: Not available
	Depth: 60.0	Pump Setting Depth: Not available	Water Quality: Not available
Casing	Length: 48.0	Material: Not available	Diameter: 36.0
Screen	Length: 12.0	Material: Not available	Diameter: 18.0
	Slot Size: J SS .090		

Well Capacity Test	Type of Test: Not available	Test Rate: 305.0 gpm	Bail Test Rate: Not available
	Drawdown: 32.5 ft.	Static Water Level: 10.0 ft.	Bailer Drawdown: Not available

Grouting Information	Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Well Abandonment	Sealing Material: Not available	Depth: From (not available) To (not available)
	Installation Method: Not available	Number of Bags Used: Not available

Administrative	County: MARION	Township: 16N
	Range: 2E	Section: SW of the NE of the SW of Section 36
	Topo Map: CLERMONT	Grant: Not available
	Field Located By: Not available	Field Located On: Not available
	Courthouse Location By: Not available	Courthouse Location On: Not available
	Location Accepted w/o Verification By: UCH	Location Accepted w/o Verification On: 2/1/1973
	Subdivision Name: SPEEDWAY	Lot Number: #8
	Ft W of EL: Not available	Ft N of SL: Not available
	Ft E of WL: Not available	Ft S of NL: Not available
	Ground Elevation: 723.0	Depth of Bedrock: Not available
	Bedrock Elevation: Not available	Aquifer Elevation: 665.0
	UTM Easting: 563066	UTM Northing: 4403810

Well Log

Top	Bottom	Formation
0.0	15.0	TOP SOIL SAND & GRAV&LOGS
15.0	45.0	HARD CLAY & BOULDERS
45.0	48.0	FINE GRAV
48.0	58.0	MED S&G

Comments
None

Record of Water Well

Indiana Department of Natural Resources

Reference Number Driving directions to well
179985

Date completed
 Jul 01, 1962

Owner- Contractor	Name	Address	Telephone
Owner	EVANS MILLING CO.	1730 WEST MICHIGAN ST.	
Driller	CHARLES KRAUSS & SONS	402 WEST 9TH ST. INDPLS, IN	
Operator	HARVEY WOLF	License: null	

Construction Details

Well	Use: Industry	Drilling method: Cable Tool	Pump type:
	Depth: 340.0	Pump setting depth:	Water quality:
Casing	Length: 104.0	Material:	Diameter: 12.0
Screen	Length: 8.0	Material:	Diameter: 12.0 Slot size: 75

Well Capacity Test	Type of test: Pumping	Test rate: 300.0 gpm for 10.0 hrs.	BailTest rate: gpm for hrs.
	Drawdown: 15.0 ft.	Static water level: 35.0 ft.	Bailer Drawdown ft.

Grouting Information	Material:	Depth: from to
	Installation Method:	Number of bags used:

Well Abandonment	Sealing material:	Depth: from to
	Installation Method:	Number of bags used:

Administrative	County: MARION	Township: 15N Range: 3E
	Section: SE of the NW of the NW of Section 3	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by: JMT	on:
	Courthouse location by:	on:
	Location accepted w/o verification by:	on:
	Subdivision name:	Lot number:
	Ft W of EL:	Ft E of WL: 1400.0
	Ft N of SL: 4200.0	Ft S of NL:
	Ground elevation: 700.0	Bedrock elevation: 600.0
Depth to bedrock: 100.0	Aquifer elevation:	
UTM Easting: 569192.6	UTM Northing: 4403170.5	

Well Log	Top	Bottom	Formation
	0.0	3.0	FILL
	3.0	10.0	CLAY YELLOW
	10.0	25.0	GRAVEL DRY
	25.0	40.0	SAND WATER BEARING
	40.0	65.0	GRAVEL CLAY BLUE
	65.0	70.0	CLAY BLUE
	70.0	72.0	SAND & GRAVEL MUDDY
	72.0	85.0	CEMENTED GRAVEL

85.0	93.0	WATER GRAVEL & SAND
93.0	100.0	CLAY SANDY
100.0	105.0	LIME BROKEN
105.0	150.0	LIME GRAY
150.0	300.0	LIME BLUE
300.0	320.0	LIME WHITE
320.0	340.0	LIME SOFT PUTTY

Comments

MC 600

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving directions to well	Date completed
414789	ON 18TH ST W OF N CENTENNIAL (3351 W 18TH INDIANAPOLIS, IN)	Jun 11, 2008

Owner-Contractor	Name	Address	Telephone
Owner	ERNIE PYLE SCHOOL		
Driller	ORTMAN DRILLING	241 N 300 W KOKOMO, IN	(765) 459-4125
Operator	MIKE KELLER-NATHAN MCDORMAN-AD	License: 2050	

Construction Details

Well	Use: Other	Drilling method:	Pump type:
	Depth: 130.0	Pump setting depth:	Water quality: CLEAR
Casing	Length: 110.0	Material: PVC	Diameter: 6.0
Screen	Length: 20.0	Material: STEEL	Diameter: 6.0 Slot size:

Well Capacity Test	Type of test: Air	Test rate: 200.0 gpm for 10.0 hrs.	BailTest rate: gpm for hrs.
	Drawdown: ft.	Static water level: 37.1 ft.	Bailer Drawdown ft.

Grouting Information	Material: BENSEAL	Depth: from 50.0 to 0.0
	Installation Method: PUMPED	Number of bags used: 8.0

Well Abandonment	Sealing material: NORTHERN SILICA	Depth: from 130 to 50
	Installation Method: WASHED IN	Number of bags used: 400.0

Administrative	County: MARION	Township: 16N Range: 3E
	Section: SW of the SW of the NW of Section 33	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by: DRILLER	on: Jun 11, 2008
	Courthouse location by:	on:
	Location accepted w/o verification by:	on:
	Subdivision name:	Lot number:
	Ft W of EL:	Ft E of WL:
	Ft N of SL:	Ft S of NL:
	Ground elevation: 733.0	Bedrock elevation: 603.0
	Depth to bedrock: 130.0	Aquifer elevation:
	UTM Easting: 567268.0	UTM Northing: 4404385.0

Well Log	Top	Bottom	Formation
	0.0	2.0	BROWN CLAY
	2.0	25.0	M-C SAND AND GRAVEL W/BOULDERS
	25.0	30.0	SANDY GRAY CLAY
	30.0	45.0	M-C SAND AND GRAVEL W/COBBLES
	45.0	82.0	SANDY GRAY CLAY
	82.0	85.0	F-M SAND AND GRAVEL
	85.0	94.0	SANDY GRAY CLAY

94.0	100.0	F-M SAND AND GRAVEL W/CLAY
100.0	130.0	F-M SAND AND GRAVEL
130.0		LIMESTONE

Comments

Record of Water Well

Indiana Department of Natural Resources

Reference Number 414788 **Driving directions to well** ON 18TH ST W OF N CENTENNIAL (3351 W 18TH INDIANAPOLIS, IN) **Date completed** Jun 13, 2008

Owner-Contractor	Name	Address	Telephone
Owner	ERNIE PYLE SCHOOL		
Driller	ORTMAN DRILLING	241 N 300 W KOKOMO, IN	(765) 459-4125
Operator	MIKE KELLER-NATHAN MCDORMAN-AD	License: 2050	

Construction Details

Well	Use: Other	Drilling method:	Pump type:
	Depth: 130.0	Pump setting depth:	Water quality: CLEAR
Casing	Length: 110.0	Material: PVC	Diameter: 6.0
Screen	Length: 20.0	Material: STEEL	Diameter: 6.0 Slot size: .04

Well Capacity Test	Type of test: Air	Test rate: 200.0 gpm for 10.0 hrs.	Bail Test rate: gpm for hrs.
	Drawdown: ft.	Static water level: 37.7 ft.	Bailer Drawdown ft.

Grouting Information	Material: BENSEAL	Depth: from 50.0 to 0.0
	Installation Method: PUMPED	Number of bags used: 8.0

Well Abandonment	Sealing material: NORTHERN SILICA	Depth: from 13 to 50
	Installation Method: WASHED IN	Number of bags used: 2.0

Administrative	County: MARION	Township: 16N Range: 3E
	Section: SW of the SW of the NW of Section 33	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by: DRILLER	on: Jun 13, 2008
	Courthouse location by:	on:
	Location accepted w/o verification by:	on:
	Subdivision name:	Lot number:
	Ft W of EL:	Ft N of SL:
	Ground elevation: 733.0	Depth to bedrock: 130.0
	UTM Easting: 567268.0	Bedrock elevation: 603.0
		Aquifer elevation:
		UTM Northing: 4404391.0

Well Log	Top	Bottom	Formation
	0.0	2.0	BROWN CLAY
	2.0	45.0	M-C SAND AND GRAVEL W/COBBLES
	45.0	65.0	GRAY CLAY W/GRAVEL
	65.0	92.0	GRAY CLAY W/GRAVEL
	92.0	100.0	GRAVELY GRAY CLAY
	100.0	130.0	F-M SAND & GRAVEL
	130.0		LIMESTONE

Comments

Record of Water Well

Indiana Department of Natural Resources

Reference Number 54035	Driving directions to well S OF MICHIGAN ST ON ROENA TO VERMONT. E TO 4044 W VERMONT.	Date completed Jan 29, 1981
---	--	---------------------------------------

Owner-Contractor	Name	Address	Telephone
Owner	ALBERT RAY	4044 W VERMONT, INDPLS IN	
Driller	MILLS PUMP & WELL DRILLING INC	2508 W MICHIGAN ST, INDPLS IN	
Operator	RUSSELL MILLS	License: null	

Construction Details

Well	Use: Home	Drilling method: Rotary	Pump type:
	Depth: 75.0	Pump setting depth:	Water quality:
Casing	Length: 72.0	Material:	Diameter: 4.0
Screen	Length: 3.0	Material:	Diameter: 4.0 Slot size: 40

Well Capacity Test	Type of test:	Test rate: gpm for hrs.	BailTest rate: 10.0 gpm for 1.0 hrs.
	Drawdown: ft.	Static water level: 20.0 ft.	Bailer Drawdown 10.0 ft.

Grouting Information	Material:	Depth: from to
	Installation Method:	Number of bags used:

Well Abandonment	Sealing material:	Depth: from to
	Installation Method:	Number of bags used:

Administrative	County: MARION	Township: 15N Range: 3E	
	Section: NW of the NE of the SW of Section 5	Topo map: INDIANAPOLIS WEST	
	Grant Number:		
	Field located by: MCBN	on: Jan 01, 1992	
	Courthouse location by:	on:	
	Location accepted w/o verification by: BRUNS	on: Dec 21, 1982	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL: Ft S of NL:
	Ground elevation: 717.0	Depth to bedrock:	Bedrock elevation: 642.0
	UTM Easting: 566010.0		UTM Northing: 4402525.0

Well Log	Top	Bottom	Formation
	0.0	1.0	BLANK
	1.0	21.0	CLAY GRAY
	21.0	70.0	CLAY BLUE
	70.0	75.0	SAND BLUE

Comments

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving directions to well	Date completed
54034	4017 COSSELL RD	Mar 23, 1977

Owner-Contractor	Name	Address	Telephone
Owner	ALBERT SOLEMAN		
Driller	HAMILTON BROS	PO BOX 24181 INDPLS, IND	
Operator	INC	46224	
	WOODIE BURKHART	License: null	

Construction Details

Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 54.0	Pump setting depth:	Water quality:
Casing	Length:	Material:	Diameter: 4.0
Screen	Length:	Material:	Diameter: 3.0 Slot size:

Well Capacity Test	Type of test:	Test rate: 10.0 gpm for 1.0 hrs.	BailTest rate: gpm for hrs.
	Drawdown: ft.	Static water level: ft.	Bailer Drawdown ft.

Grouting Information	Material:	Depth: from to
	Installation Method:	Number of bags used:

Well Abandonment	Sealing material:	Depth: from to
	Installation Method:	Number of bags used:

Administrative	County: MARION	Township: 15N Range: 3E
	Section: NW of the NE of the SW of Section 5	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by: MCBH	on: Jan 01, 1992
	Courthouse location by:	on:
	Location accepted w/o verification by: WH	on: Jul 07, 1977
	Subdivision name:	Lot number:
	Ft W of EL:	Ft N of SL:
	Ground elevation: 717.0	Depth to bedrock:
	UTM Easting: 566060.0	Bedrock elevation:
		Aquifer elevation: 663.0
		UTM Northing: 4402550.0

Well Log	Top	Bottom	Formation
	0.0	35.0	TOPSOIL & CLAY
	35.0	54.0	S & G

Comments

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving directions to well	Date completed
54036	4012 COSSELL RD.	Jan 13, 1977

Owner-Contractor Name	Address	Telephone
Owner	LEON PEDIGO	
Driller	HAMILTON BROS INC.	PO BOX 24181, INDPLS IN
Operator	ED RANDOLPH	License: null
Company	PEDIGO & YOUNG	

Construction Details

Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 62.0	Pump setting depth:	Water quality:
Casing	Length: 59.0	Material:	Diameter: 4.0
Screen	Length: 3.0	Material:	Diameter: 4.0 Slot size: .060

Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.0 hrs.	BailTest rate: gpm for hrs.
	Drawdown: ft.	Static water level: ft.	Bailer Drawdown: ft.

Grouting Information	Material:	Depth: from to
	Installation Method:	Number of bags used:

Well Abandonment	Sealing material:	Depth: from to
	Installation Method:	Number of bags used:

Administrative	County: MARION	Township: 15N Range: 3E
	Section: SW of the SE of the NW of Section 5	Topo map:
		INDIANAPOLIS WEST
	Grant Number:	
	Field located by: MCBN	on: Jan 01, 1992
	Courthouse location by:	on:
	Location accepted w/o verification by: WH	on: Jul 07, 1977
	Subdivision name:	Lot number:
	Ft W of EL:	Ft E of WL: Ft S of NL:
	Ft N of SL:	Bedrock
	Ground elevation: 717.0	elevation: Aquifer elevation: 655.0
	Depth to bedrock:	
	UTM Easting: 566060.0	UTM Northing: 4402600.0

Well Log	Top	Bottom	Formation
	0.0	1.0	TOPSOIL & CLAY
	1.0	35.0	S&G
	35.0	62.0	BR CLAY

Comments

